STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	155249	A. BUILDING **01** B. WING _____	R **01/09/2014**

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
SIGNATURE HEALTHCARE OF FORT WAYNE	**6006 BRANDY CHASE COVE** **FORT WAYNE, IN 46815**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	INITIAL COMMENTS	{K 000}		

A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 11/13/13 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).

Survey Date: 01/09/14

Facility Number: 000153
Provider Number: 155249
AIM Number: 100266910

Surveyor: Amy Kelley, Life Safety Code Specialist

At this PSR survey, Signature Healthcare of Fort Wayne was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.

This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, in areas open to the corridors and hard wired smoke detectors in the resident rooms. The facility has a capacity of 160 and had a census of 85 at the time of this survey.

All areas providing customary access to the residents were sprinklered. The facility had a detached garage and three sheds providing facility services including storage of old

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE | TITLE | (X6) DATE

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	155249	A. BUILDING **01** B. WING _____	R **01/09/2014**

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
SIGNATURE HEALTHCARE OF FORT WAYNE	**6006 BRANDY CHASE COVE** **FORT WAYNE, IN 46815**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	Continued From page 1 equipment, new beds, mattresses and maintenance supplies that were not sprinklered. Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 01/13/14.	{K 000}		